

# Water & Wastewater System Capacity




# Background – History of Systems

- The Windsor, Falmouth and Hantsport Utilities operate independent water supply systems.
- All surface water
- Windsor (incl TMP) services app. 6,500 residents, constructed 1890
- Falmouth services 1368 residents, constructed in 1969
- Hantsport services 1560 residents, constructed in early 1900's




# High Level Timeline +++



# Storage Requirement

4,079 m<sup>3</sup> or 4,079,000 liters



**RESERVOIR STORAGE SCHEMATIC**

# Water Demands Windsor- Trend

**Table 5: Summary of Historical Demands**

Year	Town of Windsor	Three Mile Plains	Windsor WTP		
	ADD (MLD)	ADD (MLD)	ADD (MLD)	MDD (MLD)	MDF
2015	-		3.52	5.67	1.61
2016	2.00	1.12	3.12	5.31	1.71
2017	2.33	1.19	3.52	5.18	1.47
2018	2.10	1.25	3.35	5.61	1.67
2019	2.39	1.36	3.75	5.70	1.52
2020	-	-	3.03	4.28	1.41

# Water System Demands

Windsor 52% - TMP 36% (and growing)

Table 6: Summary of Current and Future Demands

Demands	Current (MLD)	Future (2040) (MLD)
<b>Total ADD</b>	<b>3.38</b>	<b>4.13</b>
Industrial Park (est.)	0.40	0.49
Three Mile Plains	1.21	1.48
Windsor	1.77	2.16
<b>Total MDD</b>	<b>5.29</b>	<b>6.46</b>
Industrial Park (est.)	0.63	0.77
Three Mile Plains	1.90	2.32
Windsor	2.77	3.38

# Falmouth Demands - Trend

**Table 1: Summary of Historical Demands**

Year	Estimated Population	ADD (MLD)	MDD (MLD)	MDF
2015	-	0.62	1.01	1.64
2016	1,368 (census)	0.65	1.14	1.74
2017	-	0.63	1.66	2.64
2018	-	0.64	1.38	2.16
2019	-	0.71	1.21	1.72
2020	1,585 <sup>1</sup>	0.74	1.40	1.88

1. The number of service connections in 2020 is 780. With an estimated population of 1585 based on 3.75% annual growth, this equates to 2.0 persons per connection.

# Falmouth System Demands - 2040

**Table 2: Current and Future Demands**

Year	Current	Future (2040)
ADD (MLD)	0.74	1.22
MDD (MLD)	1.40	2.40
MDF	1.88	1.97

# Interconnecting Falmouth & Windsor

**Table 13: Combined System Flow Balancing Table**

Scenario	Windsor	Falmouth	Combined	Windsor to Falmouth Net Flow (m <sup>3</sup> )	
				(FWTP @ 1.0 MLD)	(FWTP @ 2.2 MLD)
<b>Current ADD (MLD)</b>	3.38	0.74	4.12	-0.26	-1.46
<b>Current MDD (MLD)</b>	5.29	1.40	6.69	0.40	-0.80
<b>5-Year Projection</b>					
<b>Population</b>	3,834	1,793	5,627	-	-
<b>Future ADD (MLD)</b>	3.55	0.84	4.39	-0.16	-1.36
<b>Future MDD (MLD)</b>	5.56	1.58	7.15	0.58	-0.62
<b>20-Year Projection</b>					
<b>Population</b>	4,451	2,597	7,048	-	-
<b>Future ADD (MLD)</b>	4.13	1.22	5.34	0.22	-0.99
<b>Future MDD (MLD)</b>	6.46	2.39	8.85	1.39	0.19
<b>Available Average WTP Flow (MLD)</b>	5.40	1.00	6.40		
<b>Maximum Available Daily WTP Flow (MLD)</b>	6.80	2.20	9.00		



# Planning for the future growth

- Additional Storage Tank in Windsor
- Dam upgrades and meeting DFO regulations
- Interconnect Windsor and Falmouth Distribution systems
- 3<sup>rd</sup> Process Train at the Windsor Treatment Facility
- Water Conservation efforts and leak detection
- Pressure Management
- 20-year master integrated resource plan – Water, WW and Storm
- Exploring additional potable water source of supplies – (Dal Students)
- Exploring potential to increase existing yield in current watersheds



# Development Reviews

<b>Windsor WTP</b>						
Max Design Flow	6792m <sup>3</sup> /day					
Storage Capacity	Clearwell 1818m <sup>3</sup> , Standpipe 1400m <sup>3</sup>					
Withdrawal Limits	6800m <sup>3</sup> /day					
	2018	2019	2020	2021	2022	* Average Usage with Projected Development
Annual Average Daily Flow m <sup>3</sup>	3365	3761	2977	3107	3460	5567
Annual Total Flow <sup>3</sup>	1228304	1373027	1086628	1133940	1262790	2031904
% Maximum Design Capacity	49.5	55.3	43.8	45.7	50.9	81.9
% Withdrawal Rate	49.5	55.3	43.8	45.7	50.9	81.9
* Based on most recent annual average data and projected annual usage from new development						

# Development Reviews

Falmouth WTP						
Max Design Flow	2160m <sup>3</sup> /day					
Storage Capacity	Clearwell 205m <sup>3</sup> , Standpipe 2942m <sup>3</sup>					
Withdrawal Limits	1000m <sup>3</sup> /day					
	2018	2019	2020	2021	2022	*Average Usage with Projected Development
Annual Average Daily Flow m <sup>3</sup>	631	706	720	757	859	947
Annual Total Flow <sup>3</sup>	230139	257714	262958	276478	313520	308666
% Maximum Design Capacity	29.2	32.7	33.3	35.1	39.7	43.9
% Withdrawal Rate	63.1	70.6	72	75.75	85.9	94.7
* Based on most recent annual average data and projected annual usage from new development						

# Development Reviews

<b>Hantsport WTP</b>						
Max Design Flow	1365m <sup>3</sup> /day					
Storage Capacity	Clearwell 136m <sup>3</sup> , Standpipe 1052m <sup>3</sup>					
Withdrawal Limits	850m <sup>3</sup> /day					
	2018	2019	2020	2021	2022	* Average Usage with Projected Development
Annual Average Daily Flow m <sup>3</sup>	634	581	535	636	550	757
Annual Total Flow <sup>3</sup>	231589	212272	195172	232454	200789	259341
% Maximum Design Capacity	46.4	42.5	39.2	46.6	40.3	55.4
% Withdrawal Rate	74.5	68.4	62.9	74.8	64.7	89.0
* Based on most recent annual average data and projected annual usage from new development						

# Development Reviews

<b>Windsor Headworks Wastewater Facility</b>						
Max Design Flow	18545m <sup>3</sup> /day					
	2018	2019	2020	2021	2022	* Average Usage with Projected Development
Annual Average Daily Flow m <sup>3</sup>	2606.34	2694.96	1975.08	2466.48	2298.23	2371.14
Annual Total Flow <sup>3</sup>	951314	983659	720903	758378	838854	865466.88
% Maximum Design Capacity	14.05%	14.53%	10.65%	13.30%	12.39%	12.79%

# Development Reviews

<b>Windsor Lagoons Wastewater Facility</b>						
Max Design Flow	9400m <sup>3</sup> /day					
	2018	2019	2020	2021	2022	* Average Usage with Projected Development
Annual Average Daily Flow m <sup>3</sup>	2806.77	2511.33	2226.07	2466.48	2650.76	3132.78
Annual Total Flow <sup>3</sup>	1024470	916637	812517	900265	967526	1143462.94
% Maximum Design Capacity	29.86%	26.72%	23.68%	26.24%	28.20%	33.33%



# Development Reviews

Falmouth Wastewater Facility						
Max Design Flow	723.5m <sup>3</sup> /day					
	2018	2019	2020	2021	2022	* Average Usage with Projected Development
Annual Average Daily Flow m <sup>3</sup>	687.64	569.74	556.95	418.59	558.41	624.29
Annual Total Flow <sup>3</sup>	250987	207955	203285	152785	203820	227864.38
% Maximum Design Capacity	95.04%	78.75%	76.98%	57.86%	77.18%	86.29%

# Existing System 1:100 Year CC

## Storm Water and Collection System

- Ongoing work to separate and reconstruct aging infrastructure
- Design with Climate Change considerations
- Current storm water study
- Inflow and Infiltration reduction
- Sump pumps, foundation leaks
- System Maintenance
- Storm Water Management
- Pre / Post Development
- Major Infrastructure Investments





# Questions?

